

Pictograph (Running Man) Exit Signs as Required by the 2012 BCBC

February 21, 2014

This protocol addresses the upgrading and installation of exit signs.

1. All exit signs installed after December 20, 2012 in new construction shall be of the pictogram type (green running man exit signs) as specified in sentences 3.4.5.1. (2) or 9.9.11.3. (2) of the 2012 BCBC.
2. For tenant improvements, renovations, and additions any new or relocated exit signs are required to comply with the 2012 BCBC. Existing exits signs used or repositioned in the same location may be retained. A mixture of new and old signs may exist until such time as the existing signs are also replaced.

All replacement exit signs shall comply with the 2012 BCBC requirements

"Avy Woo"

Avy Woo
Chief Building Official